

Lead and Copper Sampling Data June - September 2025

Cobb County- Marietta Water Authority and the Consecutive
Systems of: Cobb County, City of Marietta, City of Smyrna, City
of Austell and City of Mountain Park

Results

Required Count: Total 50	Lead _{ppb}	Copper _{ppm}
1	0	0.0038
2	0	0.0092
3	0	0.01
4	0	0.012
5	0	0.013
6	0	0.014
7	0	0.014
8	0	0.014
9	0	0.014
10	0	0.015
11	0	0.016
12	0	0.017
13	0	0.017
14	0	0.017
15	0	0.018
16	0	0.018
17	0	0.018
18	0	0.018
19	0	0.02
20	0	0.021
21	0	0.021
22	0	0.021
23	0	0.021
24	0	0.022
25	0	0.022
26	0	0.022
27	0	0.023
28	0	0.023
29	0	0.025
30	0	0.031
31	0	0.033
32	0	0.034
33	0	0.036
34	1	0.037
35	1	0.038
36	1.2	0.04
37	1.3	0.044
38	1.3	0.044
39	1.5	0.05
40	1.7	0.058
41	1.8	0.068
42	1.9	0.071
43	2	0.073
44	2.9	0.075

45	2.9	0.078
46	3.3	0.08
47	3.8	0.083
48	14	0.1
49	24	0.11
50	37	0.47

AL

Lead 90th Percentile:

2.9	15 ppb
0.078	1.3 ppm

Copper 90th Percentile:

ppb - Parts Per Billion

ppm - Parts Per Million

AL - Action Level for meeting compliance